

Scope of Accreditation for the Testing Laboratory (Center) / Medical Laboratory

Testing Center of All-Russia Electrotechnical Institute –
the Branch of the Federal State Unitary Enterprise
“Russian Federal Nuclear Center – Zababakhin All-Russia Research Institute of Technical Physics”

Testing laboratory (center) / medical laboratory name

111250. Moscow, Krasnokazarmennaya Street 12, Blds. 3, 7, 8

Business address

for Compliance with GOST ISO/IEC 17025-2019

Title and reference details of an international or national standard establishing general requirements for the competence of testing and calibration laboratories / individual requirements to the quality and competence of medical laboratories

§§	Documents establishing rules and techniques of research (testing) and measurements	Equipment	OKPD ¹ 2 code	TN VED EAEU ² code	Defined parameter	Range
1	2	3	4	5	6	7
111250, Moscow, Krasnokazarmennaya Street 12, Blds. 3, 7						
1	GOST R 55191 Clauses 5, 8	Electrical equipment and installations for alternating voltages greater than 1000 V	27.11 27.12 27.32 27.90	8501 8504 8535	Partial discharge	1 pC to 10 nC
2	GOST R 55190 Subclause 8.3.1	Metal-enclosed switchgear	27.12	8535 8537	Temperature rise and temperature at current flow across the main circuit	0 °C to 300 °C
3	GOST R 55190				Test current	100 A to 12000 A
					Contact resistance of the auxiliary circuits	exceeds/does not exceed

¹ Russian Classification of Products by Economic Activity Type

² Eurasian Economic Union's Commodity Nomenclature of Foreign Economic Activity

1	2	3	4	5	6	7
	Subclauses 8.3.2.1, 8.3.2.2					1 $\mu\Omega$ to 1999.9 Ω 0.1 mA to 100 A
4	GOST R 55190 Subclause 8.3.2.3				Temperature-rise test of the auxiliary and control equipment	exceeds/does not exceed 0 °C to 300 °C 0 V to 500 V
5	GOST R 55190 Subclause 8.4.5.1				Switchgear closing and opening times	0.1 ms to 10 c
6	GOST R 55190 Subclause 8.4.8				Operability of locking devices	passed/failed 0 kN to 1 kN 0 V to 500 V
7	GOST R 55190 Subclause 8.4.9				Operability of fixing devices	passed/failed 0 to 1 kN
8	GOST R 55190 Subclause 8.4.10				Pressure continuity of sliding earthing contacts	passed/failed 0.02 mm to 0.5 mm 1 $\mu\Omega$ to 1999.9 Ω 1 mA to 100 A
9	GOST R 55190 Subclauses 8.5.1 – 8.5.13				Insulation strength Test power-frequency AC voltage Test impulse voltage Partial discharge measurement	passed/failed 0 to 300 kV 3 kV to 200 kV 1 pC to 10 nC
10	GOST R 55190 Subclause 8.6				Short-circuit dynamic and short-time thermal currents: – dynamic current – short-time thermal current – short-time thermal current	passed/failed 0 kA to 200 kA (0 s to 0.5 s) 0 kA to 51 kA (0 s to 3.3 s) 0 kA to 100 kA (0 s to 1.1 s)
11	GOST R 55190 Subclause 8.7.4				Mechanical strength of air terminal elements	passed/failed 0 kN to 5 kN
12	GOST R 55190 Subclause 8.7.6				Corrosion resistance	passed/failed 20 °C to 40 °C 60% to 98 %
13	GOST R 55190 Subclause 8.9.1				Switching capacity	passed/failed 0 kA to 63 kA 0 kV to 35 kV
14	GOST R 55190 Subclause 8.9.2				Auxiliary transformer no-load current breaking capacity	passed/failed 0 A to 3 A
15	GOST R 55190 Subclause 8.11				Arc resistance at internal short-circuit	passed/failed 0 kA to 63 kA

1	2	3	4	5	6	7
						0 kV to 35 kV
16	GOST R 52565 Subclauses 9.10.2.1, 9.10.2.2, 9.10.5	Three-phase 50 Hz AC circuit-breakers of rated voltages 3 and up to and including 750 kV	27.12.10.110	8535	Resistance to the ambient temperature lower value	passed/failed -70 °C to +150 °C
17	GOST R 52565 Subclauses 9.10.2.1, 9.10.2.3, 9.10.5				Resistance to the ambient temperature upper value	passed/failed -70 to +150 °C
18	GOST R 52565 Subclause 9.7				Switching capacity at capacitance current breaking	passed/failed 0 A to 100 A 0 kV to 35 kV
19	GOST R 52565 Subclause 9.8				Switching capacity at shunt reactor current breaking	passed/failed 0 A to 100 A 0 kV to 35 kV
20	GOST R 55716 Subclause 6.4	High-voltage switchgear	27.12.10.110 27.12.10.120	8535	DC resistance	1 μΩ to 1999.9 Ω 0.1 mA to 100 A
21	GOST R 55716 Subclause 6.6				Short-circuit through current withstand: – dynamic current – short-time thermal current	passed/failed 0 kA to 200 kA passed/failed 0 kA to 100 kA
22	GOST 2213 Subclause 7.1	AC fuses for voltages greater than 3 kV	27.12.10.140	853610	Geometrical dimensions Mass Protective coating condition Surface condition of external insulation parts Correctness of nameplates Correctness of marking Availability of operation indicator	0 mm to 10000 mm 0.05 kg to 500 kg normal/defective (visual check) normal/defective (visual check) correct/incorrect (visual check) correct/incorrect (visual check)
	GOST 2213 Subclause 7.2				DC resistance	1 μΩ to 1999.9 Ω 0.1 mA to 100 A
	GOST 2213 Subclause 7.5				Temperature rise and temperature in rated current-induced heating test	0 °C to 300 °C 100 A to 12000 A
23	GOST 14694 Clause 3	Metal-enclosed switchgear	27.12	8535 8537	Temperature Test current	passed/failed 0 °C to 300 °C 50 A to 12000 A

1	2	3	4	5	6	7
24	GOST 14694 Subclause 4.2				Travel and alignment of main-circuit detachable contacts	0.1 mm to 1000 mm
25	GOST 14694 Clause 11				Quality of corrosion protection and painting	passed/failed 20 °C to 40 °C 60 % to 98 %
26	GOST 14694 Clause 12				Localization capacity	passed/failed 0 kA to 31.5 kA 0 kV to 35 kV
27	Operation guide “SMR-1 pressure force gauge”, Subclause 5.2	Metal-enclosed switchgear and AC disconnectors and earthing switches	27.12	8535 8537 853530	Pressure force for direct plug-in contacts	50 N to 500 N
28	GOST 19264-82 Subclause 7.2	Control electromagnets	27.33.13.160	850590	Completeness Quality of assembly, finishing, and soldering Protective coating condition Reliability of fixtures Correctness of marking Proper arrangement of contact connections Geometrical dimensions Mass	compliant/noncompliant passed/failed normal/defective passed/failed correct/incorrect correct/incorrect 0 mm to 10000 mm 0 kg to 5000 kg
	GOST 19264-82 Subclause 7.4				Insulation resistance	3 kΩ to 1000 GΩ
	GOST 19264-82 Subclause 7.5				Insulation strength at power-frequency voltage	passed/failed 100 V to 6000 V
	GOST 19264-82 Subclause 7.6				DC resistance	1 μΩ to 9.99 kΩ 0.1 mA to 100 A
	GOST 19264-82 Subclause 7.7				Electric current consumed power	0 A to 100 A 0 kW to 100 kW
	GOST 19264-82 Subclause 7.8				DC resistance Ambient air temperature Power supply voltage Closing time	1 μΩ to 1999.9 Ω +5 °C to +40 °C 0 V to 6000 V 0.1 ms to 10 s
29	GOST 30630.1.2 Subclause 4.6 (method 102-4)	Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51. 26.80. 27.11.	8501 8502 850300 8504 8505	Resistance to sinusoidal frequency vibration	passed/failed 1.5 m·s ⁻² to 400 m·s ⁻² 5 Hz to 600 Hz maximum displacement 6 mm
					Resistance to wide-band random vibration	passed/failed 1.5 m·s ⁻² to 400 m·s ⁻²

1	2	3	4	5	6	7
	GOST 30630.1.2 Subclause 5.10 (method 103-2.1)		27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.31. 29.32		Vibration survival strength at fixed-frequency sinusoidal vibration	5 Hz to 600 Hz maximum displacement 6 mm passed/failed 1.5 m·s ⁻² to 400 m·s ⁻² 5 Hz to 600 Hz maximum displacement 6 mm
30	GOST R IEC 60068-2-1 Clauses 4, 5, 6, 8	Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51. 26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.10. 29.31. 29.32	8504 8535 8536 8546 8504 8535 8536 8546	Resistance to the ambient temperature lower value in service Resistance to the ambient temperature lower value in transportation and storage	passed/failed -75 °C to +150 °C passed/failed -75 °C to +150 °C
31	GOST R IEC 60068-2-2 Clauses 4, 5, 6, 8	Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51. 26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.10. 29.31. 29.32	8504 8535 8536 8546 8504 8535 8536 8546	Resistance to the ambient temperature lower value in service Resistance to the ambient temperature lower value in transportation and storage	passed/failed от -75 °C to +150 °C passed/failed от -75 °C to +150 °C
32	GOST R IEC 60068-3-8 Clauses 4, 5, 6, 7, 8	Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30.	8504 8535 8536 8546 8504	Resistance to vibration	passed/failed 1.5 m·s ⁻² to 400 m·s ⁻² 5 Hz to 600 Hz maximum displacement

1	2	3	4	5	6	7
			26.40. 26.51. 26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.31. 29.32	8535 8536 8546	Vibration survival strength	6 mm passed/failed $1.5 \text{ m}\cdot\text{s}^{-2}$ to $400 \text{ m}\cdot\text{s}^{-2}$ 5 Hz to 600 Hz maximum displacement 6 mm
33	GOST 14254 Clause 13	Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91.	8504 8535	Degrees of protection against external solid objects designated by the first characteristic digit	passed/failed IP1X. IP2X. IP3X. IP4X
34	GOST 14254 Clause 15		25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51. 26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.10. 29.31. 29.32	8536 8546 8504 8535 8536 8546	Degrees of protection against access to hazardous parts (designated by an additional letter)	passed/failed A. B. C. D
35	GOST 30630.0.0 Clauses 4, 7, Subclauses 8.1-8.9	Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51. 26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.10. 29.31. 29.32	8504 8535 8536 8546 8504 8535 8536 8546	Resistance to the ambient temperature lower value in service Resistance to the ambient temperature lower value in transportation and storage Resistance to the ambient temperature lower value in service Resistance to the ambient temperature lower value in transportation and storage Resistance to ambient temperature change Resistance to long-term and accelerated exposure to air humidity or in dew-fall conditions Resistance to short-term exposure to air humidity	passed/failed $-75 \text{ }^\circ\text{C}$ to $+150 \text{ }^\circ\text{C}$ passed/failed $-75 \text{ }^\circ\text{C}$ to $+150 \text{ }^\circ\text{C}$ passed/failed $-75 \text{ }^\circ\text{C}$ to $+150 \text{ }^\circ\text{C}$ passed/failed $-75 \text{ }^\circ\text{C}$ to $+150 \text{ }^\circ\text{C}$ passed/failed 60 % to 98 % passed/failed 60 % to 98 %
36	GOST 30630.0.0					Resistance to vibration

1	2	3	4	5	6	7
	Clauses 4. 5. Subclauses 6.1-6.16				Vibration survival strength	1.5 m·s ⁻² to 400 m·s ⁻² 5 Hz to 600 Hz maximum displacement 6 mm passed/failed 1.5 m·s ⁻² to 400 m·s ⁻² 5 Hz to 600 Hz maximum displacement 6 mm
37	GOST 11828-86 Clause 2, 3 GOST 11828-86 Clause 2, 4 GOST 11828-86 Clause 2, 6 GOST 11828-86 Clause 2, 7 GOST 11828-86 Clause 2, 8 GOST 11828-86 Clause 2, 9 GOST 11828-86 Clause 2, 10	Rotating electrical machines	27.11	8501	DC resistance Ability to withstand elevated rotation speed Insulation resistance Insulation strength at power-frequency voltage Electrical strength of turn-to-turn insulation at power-frequency voltage Temperature DC resistance Ambient air temperature Temperature Frequency Shaft speed	1 μΩ to 10 kΩ 0.1 mA to 100 A passed/failed 100 rpm to 30000 rpm 3 kΩ to 1000 GΩ 50 V to 5000 V passed/failed 0 kV to 150 kV passed/failed 0 kV to 100 kV 0 °C to 300 °C 1 μΩ to 1999.9 Ω -40 °C to +85 °C 0 °C to 300 °C 3 Hz to 400 Hz 100 rpm to 30000 rpm
38	GOST IEC 61439-1 Subclause 10.2.7 GOST IEC 61439-1 Subclause 10.9 GOST IEC 61439-1 Subclause 10.10 GOST IEC 61439-1 Subclause 10.11 GOST IEC 61439-1 Subclause 10.13	Low-voltage switchgear and controlgear	27.12	8536 8537	Marking Insulation strength at power-frequency voltage Insulation strength at lightning impulse voltage Temperature rise and temperature in rated current-induced heating test Short-circuit current withstand Operability of mechanical parts	passed/failed 0 s to 60 s passed/failed 0 kV to 10 kV passed/failed 0 kV to 20 kV 0 °C to 300 °C passed/failed 0 kA to 150 kA passed/failed 100 to 300 operation cycles

1	2	3	4	5	6	7
						0 kN to 1 kN
39	GOST 17441 Subclause 2.6	Electrical contact connections	27.33.13	8504 8535 8536 8546 8504 8535 8536 8546	DC resistance	1 $\mu\Omega$ to 1000 $\mu\Omega$ 1 mA to 100 A
40	User manual "Multi-purpose scale GX-A and GF-A" Subclause 5.1	Electrotechnical products	27.11 27.12 27.32 27.90	8504 8535 8536 8546 8504 8535 8536 8546	Mass	0.02 g to 122 g
41	Operation guide "Suspended crane scale VCK-A" Clause 3	Electrotechnical products	27.11 27.12 27.32 27.90	8504 8535 8536 8546 8504 8535 8536 8546	Mass	4 kg to 500 kg
42	Operation guide VP41.00.000RE "Conductome- ter MARK-603" Subclause 2.4.1	Water and water solutions	–	–	Specific conductance of water and water solutions	0 $\mu\text{Cm}/\text{mm}$ to 2000 $\mu\text{Cm}/\text{mm}$
43	GOST R 54827 Subclause 26.3	General-purpose dry trans- former, including autotrans- formers; auxiliary station transformers; and transfor- mers for packaged transformer substations (PTS) of voltage classes up to and including 35 kV	27.11.4	8504210000 8504221000 8504229000 850423000 850431 850432000 850433000 850434000	Environmental resistance	passed/failed water specific conductance 0.1 Cm/m to 1.5 Cm/m relative humidity 85 % to 100% temperature +5 °C to +70 °C
44	GOST R 54827 Subclause 27.3, 27.4				Thermal shock load	passed/failed –60 °C to +70 °C
45	IEC 60076-11 ed. 2.0 Subclause 14.4.5				Environmental resistance: – water specific conductance	passed/failed 0.1 Cm/m to 6 Cm/m

1	2	3	4	5	6	7
					– relative humidity – temperature	or 85 % to 100% +5 °C to +70 °C
46	IEC 60076-11 ed. 2.0 Subclause 14.4.4				Thermal shock load	passed/failed –60 °C to +70 °C
47	GOST R 52719 Subclause 10.1	Power transformers (general-purpose and for special applications) and electrical reactors	27.11.4	8504210000 8504221000 8504229000 850423000 850431 850432000 850433000 850434000	Exterior Correctness of nameplates Correctness of marking and branding Geometrical dimensions	compliant/noncompliant compliant/noncompliant compliant/noncompliant 0 m to 10000 m
48	GOST 52719 Subclause 10.5				Ability to withstand inrush current	passed/failed 0 kA to 200 kA 0 kA to 100 kA
49	GOST R 59239 Clause 5	Power transformers (general-purpose and for special applications) and electrical reactors	27.11.4	8504210000 8504221000 8504229000 850423000 850431 850432000 850433000 850434000	Frequency response	10 Hz to 10 MHz 0 dB to –130 dB
50	IEC 60076-18 Clause 4					
51	GOST R ISO 3746 Annex A	Power transformers (general-purpose and for special applications) and electrical reactors	27.11.4	8504210000 8504221000 8504229000 850423000 850431 850432000 850433000 850434000	Geometrical dimensions	0 m to 50 m
52	IEC 60076-1 ed. 3.0 Annex E	Power transformers (general-purpose and for special applications) and electrical reactors	27.11.4	8504210000 8504221000 8504229000 850423000 850431 850432000 850433000 850434000	DC resistance Current Temperature	100 μΩ to 100 kΩ 0.1 mA to 100 A 0 °C to +300 °C
53	GOST 22756 Subclause 2.8	Power transformers (auto-transformers); line regulating transformers; shunt, current-	27.11.4	8504210000 8504221000 8504229000	Insulation strength at lightning impulse voltage	passed/failed 0 kV to 2250 kV
54	GOST 22756				Insulation strength at switching impulse voltage	passed/failed

1	2	3	4	5	6	7
	Subclause 2.9. 3.2	limiting, and arc-suppression reactors		850423000	Insulation strength at power-frequency voltage	750 kV to 1600 kV
55	GOST 22756 Subclause 2.10, 3.3			850431 850432000 850433000 850434000		passed/failed 0 kV to 900 kV
56	GOST 22756 Subclauses 1.5.3, 1.5.4, 2.7.2, 2.7.3, 2.7.7.					Short-time induced alternating voltage
57	GOST 10390 Subclauses 4.2, 4.5 – 4.11, Clause 5	Power transformers; current and voltage transformers; reactors; gears; capacitors; cable boxes; and porcelain, glass and polymer insulators and insulating structures	27.11.4	8504 8535 8536 8546	External insulation strength in polluted and humidity conditions 50% discharge voltage in conditions of contamination	passed/failed 1 kV to 500 kV
58	GOST R 55194 Subclauses 4.1, 4.4	50 Hz AC electrical equipment and installations and their parts of voltage class 1 to 750 kV	27.11 27.12 27.32 27.90	8504 8535 8546	Distance to foreign surrounding objects Test lightning impulse voltage Test switching impulse voltage Test power-frequency AC voltage	0 m to 50 m 0 kV to 2250 kV 750 kV to 1600 kV 0 kV to 950 kV
59	GOST 1983 Subclause 9.5	Electromagnetic and capacitor voltage transformers	27.11.42	850431 8504320002	No-load current	1 mA to 100 A
60	GOST 1983 Subclause 9.14				Quantitative gas leak of gas-filled transformers	passed/failed 0 to 1000 ppm _v
61	GOST 20248 Clause 9	Three-phase 50 Hz and 60 Hz packaged transformer substations (PTS)	27.12.3	853720	Insulation resistance	passed/failed 3 kΩ to 1000 GΩ 50 V to 5000 V
62	GOST R 52034 Subclause 7.4	Ceramic post insulators for voltages greater than 1000 V	23.43.10 27.90.12.110	8546200000	Reliability: – abrupt temperature drop – slow temperature change – mechanical bending load – mechanical torsion load – mechanical tensile load	passed/failed 50 °C to 80 °C –70 °C to +130 °C 0 kN to 500 kN 0 kN·m to 50 kN·m 0 kN to 500 kN
63	GOST 6490 Subclause 7.3.4	Line suspended cap-and-pin insulators	23.19.25 23.43.10 27.90.12.110	8546100000 8546200000	Zinc coating thickness	passed/failed 0 μm to 5000 μm
64	GOST 6490 Subclause 7.3.5				Axial and radial displacement	0.01 mm to 10 mm
65	GOST 6490 Subclause 7.4.1				Resistance to continuous spark flow	passed/failed 0 min to 5 min 0 kV to 150 kV 15 mm to 30 mm

1	2	3	4	5	6	7
66	GOST 6490 Subclause 7.5.2				Mechanical strength Mechanical disruptive force	passed/failed 0 kN to 1000 kN
67	GOST R 52082 Subclause 8.1.12	Outdoor polymer post insulators	27.90.12.110 22.19.73	8546901000	Partial discharge	passed/failed 1 pC to 10 nC
68	GOST R 52082 Subclauses 8.9.2, 8.9.4				Corrosion-protective coating quality and thickness Protective enclosure surface quality	passed/failed 0 µm to 5000 µm passed/failed
69	GOST R 52082 Subclause 8.9.3				Quality of connection between accessories and insulation part	passed/failed 0 mm to 10000 mm
70	Руководство по эксплуатации КБСUBCLAUSE427634.051-1 РЭ «Толщина покрытий магнитный ТМ-МГ4» Clause 2	Suspended insulators; sets of insulators; post, pin, rod line, and wall tube insulators	23.19.25 23.43.10 27.90.12.110	8546100000 8546200000	Corrosion-protective coating thickness	0 µm to 5000 µm
71	IEC 60060-1 ed. 3.0 Clauses 4, 6	AC electrical equipment and installations for voltages greater than 3 kV	27.11 27.12 27.32 27.90	8504 8535 8536 8546	Insulation strength at power-frequency AC voltage Test power-frequency AC voltage	passed/failed 0 kV to 950 kV
72	IEC 60060-1 ed. 3.0 Clauses 4, 7				Insulation strength at lightning impulse voltage Test lightning impulse voltage	passed/failed 3 kV to 2250 kV
73	IEC 60060-1 ed. 3.0 Clauses 4, 8				Insulation strength at switching impulse voltage Test switching impulse voltage	passed/failed 30 kV to 1600 kV
74	GOST 28779-90 Subclauses 9.1-9.4	Polymer post and rod insulators	27.90.12.110 22.19.73	8546100000 8546200000	Material flammability class	FV 0. FV 1. FV 2
75	GOST R 55189 Subclause 8.3	Polymer suspended rod line insulators and interphase spacers	27.90.12.110 22.19.73	8546901000	Radio interference	passed/failed 10 dB to 100 dB
76	GOST R 55189 Subclause 8.5.5				Climatic resistance	-70 °C to +130 °C 0 kN to 20 kN
77	GOST 28856 Subclause 5.1.3.4				Radio interference	passed/failed 10 dB to 100 dB
78	GOST 34204 Subclause 7.10	Nonlinear overvoltage suppressors for railway electric-traction network	27.12	8535	Explosion safety	passed/failed 0 kV to 12 kV 0 kA to 10 kA
79	GOST 34204 Subclause 7.15				Fire safety	passed/failed 0 kV to 12 kV 0 kA to 10 kA
80	GOST 17717 Subclause 7.7	AC load interrupters for voltages 3 to 10 kV. Common	27.12	8535	Switching capacity	passed/failed 0 kV to 12 kV

1	2	3	4	5	6	7
		specifications				0 kA to 100 kA
81	GOST 2933 Clause 8	Low-voltage electric gears. Testing methods	27.12	8536	Switching capacity	passed/failed 0 V to 700 V 0 kA to 100 kA
82	GOST IEC 60898-1 Subclause 9.3	Small-size electrical gears. Circuit-breakers for over- current protection for house- hold and similar purposes	27.12.10.110	8535	Marking permanence	passed/failed
83	GOST IEC 60898-1 Subclause 9.4				Reliability of screws, current-conducting parts, and connections	passed/failed 0 N·m to 100 N·m 0 N to 500 N
84	GOST IEC 60898-1 Subclause 9.5				Reliability of threaded terminals for external copper conductors	passed/failed 0 N·m to 100 N·m 0 N to 500 N
85	GOST IEC 60898-1 Subclause 9.6				Mechanical insulation strength in terms of protection against mechanical access to hazardous parts of equipment	passed/failed 40 V to 100 V 0 N to 100 N
86	GOST IEC 60898-1 Subclause 9.7				Water proofness	passed/failed
					Main circuit insulation resistance	0.1 Ω to 300 GΩ
					Main circuit insulation strength at AC voltage	passed/failed 100 V to 6000 V
87	GOST IEC 60898-1 Subclause 9.8	Insulation resistance and electrical strength of auxiliary circuits	passed/failed 100 V to 6000 V			
		Main circuit insulation strength at lightning impulse voltage	passed/failed			
		Leakage current across open contacts	0.33kV to 20 kV passed/failed			
88	GOST IEC 60898-1 Subclause 9.9	Temperature of parts under current flow	–40 °C to 300 °C 1 A to 10000 A			
		Ambient air temperature	–40 °C to +85 °C			
		Temperature measured by the thermometer	–40 °C to +100 °C			
		Temperature measured by the thermocouple	0 °C to +300 °C			
		Current	1 A to 10000 A			
89	GOST IEC 60898-1 Subclause 9.10	Voltage	0.1 mV to 1000 V			
		Resistance to testing cycles: – under rated burden – in release condition	passed/failed 0 to 30 cycles 0 h to 21 h			
					Time interval	0.1 ms to 1000 s
					Current	1 A to 10000 A

1	2	3	4	5	6	7
90	GOST IEC 60898-1 Subclause 9.11				Mechanical and switching wear-resistance	passed/failed 0 kA to 100 kA 0 kV to 1 kV
91	GOST IEC 60898-1 Subclause 9.12				Short-circuit current withstand	passed/failed 0 kA to 250 kA
					Switching capacity	passed/failed 0 kA to 50 kA
92	GOST IEC 60898-1 Subclause 9.14				Resistance to the ambient temperature upper value	passed/failed +40 °C to +150 °C
93	IEC 62271-1 ed. 2.1 Subclause 7.6	High-voltage switchgear and controlgear. Part 1 – Common specifications for alternating current switchgear and controlgear	27.12	8537	Short-circuit current withstand	passed/failed 0 kV to 100 kV 0 kA to 50 kA
94	IEC 62271-100 ed. 2.1 Subclauses 7.102, 7.103, 7.104, 7.105, 7.106, 7.107, 7.108, 7.109, 7.110, 7.111				Switching capacity	passed/failed 0 kA to 100 kA 0 kV to 1 kV
95	IEC/IEEE 62271-37-013 ed. 2.0 Subclause 7.6	High-voltage switchgear and controlgear. Part 37-013: Alternating current generator circuit-breakers	27.12	8537	Short-circuit current withstand	passed/failed 0 kV to 100 kV 0 kA to 50 kA
96	IEC/IEEE 62271-37-013 ed. 2.0 Subclauses 7.103, 7.104, 7.105				Switching capacity	passed/failed 0 kV to 100 kV 0 kA to 50 kA
97	IEC 60214-1 ed. 2.0 Subclause 7.2.3	Tap switching devices. Part 1 – Requirements to operating characteristics and testing methods	27.12	8535	Short-circuit current withstand	passed/failed 0 kA to 250 kA
98	IEC 62271-101 ed. 3.0 Subclauses 7.102, 7.104, 7.107, 7.108.2, 7.109, 7.110, 7.111	High-voltage switchgear. Synthetic testing	27.12	8537	Switching capacity	passed/failed 0 kV to 220 kV 0 kA to 50 kA
99	GOST 7746 Subclause 9.7	Electromagnetic current transformers for rated voltages 0.66 to 750 kV	27.11.4	8504 31 8504 32	Quantitative gas leak in gas-filled transformers	passed/failed 0 mln ⁻¹ to 1000 mln ⁻¹
100	GOST 7746 Subclause 9.2.7				Insulation strength at power-frequency AC voltage	passed/failed 0 kV to 950 kV
101	GOST R 54828 Subclause 8.6	Indoor and outdoor sulphur hexafluoride-insulated metal-	27.12	8537	Short-circuit current withstand	passed/failed 0 kA to 250 kA

1	2	3	4	5	6	7
102	GOST R 54828 Subclause 8.8.1	enclosed switchgear			Hermeticity	passed/failed 0 mln ⁻¹ to 1000 mln ⁻¹
103	GOST R 54828 Subclause 8.9.1				Radio interference	passed/failed 10 dB to 100 dB
104	GOST R 54828 Subclause 8.10.3				Electrical continuity of earthed metal parts	passed/failed 0 A to 100 A
105	GOST R 54828 Subclause 8.12				Switchgear making and breaking capacity	passed/failed 0 kV to 100 kV 0 kA to 50 kA
106	GOST R 52725 Subclause 8.11	Nonlinear overvoltage suppressors with metal-oxide nonlinear resistors	27.12.10	853540	Partial discharge	passed/failed 1 pC to 10 nC
107	GOST R 52725 Subclause 8.12				Leakage path length	passed/failed 0 mm to 100000 mm
108	GOST 34205 Subclause 7.11	Section insulators for railway overhead	27.90.12.110	853590	Resistance to water penetration: control testing with steep leading-edge impulse voltage	passed/failed 500 kV/μs to 3000 kV/μs
109	GOST R 52287 Subclause 6.4.9	Electrical bushings in reactor protective enclosure	27.90.12.1	853590	Short-time rated overcurrent	50 A to 12000 A
110	GOST R 55187 Subclause 9.17	15 to 60 Hz AC bushings for rated voltages greater than 1000 V/ Insulated bushings for rated alternating voltages greater than 1000 V	27.90.12.110	8535 90	Temperature rise in rated current-induced heating test Temperature Test current	passed/failed 0 °C to 300 °C 0 °C to 300 °C 50 A to 12000 A
111	GOST IEC 60044-1 Subclause 7.2	Current transformers	27.11.42	8504 31 8504 32	Heating in continuous operation regime Test current Temperature	passed/failed 50 A to 12000 A 0 °C to 300 °C
112	IEC 60137 ed.7 Subclause 8.8	Insulated bushings for rated alternating voltages greater than 1000 V	23.43.10 27.90.12.110 22.19.73	8546200000 8546901000	Temperature in temperature-rise test Test current	0 °C to 300 °C 50 to 12000 A
113	IEC 61869-2 ed.1 Subclause 7.2.2	Electromagnetic current transformers	27.11.4	850431 8504320002	Temperature in temperature-rise test Test current	0 °C to 300 °C 50 A to 12000 A
114	IEC 62271-1 ed.2.1 Subclauses 7.2.1-7.2.9, 7.2.12	Circuit-breakers; disconnectors; earthing devices; switchgear; and controlgear	27.12	8504 8535 8536 8546	Insulation strength	passed/failed
					Test power-frequency AC voltage	1 kV to 950 kV
					Test impulse voltage	3 kV to 2250 kV
115	IEC 62271-1 ed.2.1 Subclause 7.4.3				Earthing circuit continuity check	0.1 mA to 100 A

1	2	3	4	5	6	7
116	IEC 62271-1 ed.2.1 Subclause 7.4.4.				Measurement of DC resistance main circuit	1 $\mu\Omega$ to 1999.9 Ω 0.1 mA to 100 A
117	IEC 62271-1 ed.2.1 Subclause 7.5				Temperature of parts under current flow	0 °C to 300 °C 100 A to 12000 A
118	IEC 62271-1 ed.2.1 Subclause 7.9.1.1				Radio interference measurement Test power-frequency AC voltage	passed/failed 10 dB to 100 dB 20 kV to 400 kV
119	IEC 62271-1 ed.2.1 Subclause 7.10.5				Insulation strength of auxiliary and control circuits	passed/failed 100 V to 6000 V
120	GOST 34839 Subclause 9.3.7	Box joints and detachable connectors for power cables with impregnated paper and plastic insulation for rated voltages up to and including 35 kV	27.33.14	8535 90	Short-circuit current withstand: – dynamic current – short-time thermal current	passed/failed 0 kA to 200 kA 0 kA to 100 kA
121	GOST 34839 Subclauses 9.3.1, 9.3.2, 9.3.3, 9.3.4, 9.3.5				Insulation strength: Test power-frequency AC voltage Partial discharge measurement Test DC voltage Test lightning impulse voltage	passed/failed 0 kV to 500 kV 0 kV to 300 kV 0 kV to 70 kV 30 kV to 2250 kV
122	GOST 34839 Subclause 9.3.8				Tracking resistance Test power-frequency AC voltage	passed/failed 0 kV to 80 kV
123	GOST 3484.1 Clause 8	Power transformers (auto- transformers); line regulating transformers; and shunt, cur- rent-limiting, and arc- suppression reactors	27.11.4	8504 2 8504 3	Harmonic composition of no-load current	0 % to 100%
124	GOST 3484.2. Annex 3. Clause 2	Power transformers (auto- transformers); line regulating transformers; and shunt, cur- rent-limiting, and arc- suppression reactors	27.11.4	8504 2 8504 3	Winding resistance in transformer temperature-rise test	1 $\mu\Omega$ to 100 k Ω 0.1 mA to 100 A
125	GOST R 56738 Subclause 11.1. 11.2	Power transformers (auto- transformers); line regulating transformers; and shunt, cur- rent-limiting, and arc- suppression reactors	27.11.4	8504 2 8504 3	Short-time induced alternating voltage	passed/failed 0 kV to 900 kV 45 Hz to 200 Hz
126	GOST R 56738 Subclause 11.3				Partial discharge Long-time induced alternating voltage	1 pC to 10 nC passed/failed 0 kV to 900 kV 45 Hz to 200 Hz

1	2	3	4	5	6	7
127	GOST R 56738 Clause 12	Power transformers (auto-transformers); line regulating transformers; and shunt, current-limiting, and arc-suppression reactors	27.11.4	8504 2 8504 3	Linear terminal testing under short-time alternating voltage	passed/failed 0 kV to 900 kV
128	GOST R 54827 Clause 20	Power transformers (auto-transformers); line regulating transformers; and shunt, current-limiting, and arc-suppression reactors	27.11.4	8504 2 8504 3	Short-time induced alternating voltage	passed/failed 0 kV to 900 kV 45 Hz to 200 Hz
129	GOST R 54827 Clause 21	Power transformers (auto-transformers); line regulating transformers; and shunt, current-limiting, and arc-suppression reactors	27.11.4	8504 2 8504 3	Insulation strength at lightning impulse voltage	passed/failed 0 kV to 2250 kV
130	GOST R 54827 Clause 22	Power transformers (auto-transformers); line regulating transformers; and shunt, current-limiting, and arc-suppression reactors	27.11.4	8504 2 8504 3	Partial discharge	1 pC to 10 nC
131	IEC 60076-3 ed. 3.1 Clause 11	Power transformers (auto-transformers); line regulating transformers; and shunt, current-limiting, and arc-suppression reactors	27.11.4	8504 2 8504 3	Partial discharge Long-time induced alternating voltage	1 pC to 10 nC passed/failed 0 kV to 900 kV 45 Hz to 200 Hz
132	GOST R 55195 Subclause 4.10.2	50 Hz AC electrical equipment and installations and their parts for voltage class 1 to 750 kV	27	8504 8535 8546	Test power-frequency AC voltage in partial discharge measurement test Partial discharge	1 to 350 kV 1 pC to 10 nC

111250, Moscow, Krasnokazarmennaya Str., 12, bld. 8

133	GOST 16962.1-89 Clause 2	High-voltage electrotechnical products with open broken contacts	27.11 27.12 27.32 27.90	8535 8546	Operability when exposed to glaze-ice	passed/failed -20 °C to -7 °C 10 mm to 20 mm
134	GOST 30630.2.1	Machines; instruments; and	25.11. 25.29.	8504	Resistance to the ambient temperature upper value in	passed/failed

1	2	3	4	5	6	7
	Clause 4, GOST 30630.0.0 Clauses 4. 7, Subclauses 8.1-8.9, GOST R IEC60068-2-2 Clauses 4, 5, 6, 8	all types of miscellaneous technical products	25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51. 26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.10. 29.31. 29.32	8535 8536 8546 8504 8535 8536 8546	service	-75 °C to +130 °C
135	GOST 30630.2.1 Clause 5, GOST 30630.0.0 Clauses 4. 7, Subclauses 8.1-8.9, GOST R IEC 60068-2-2 Clauses 4, 5, 6, 8				Resistance to the ambient temperature upper value in transportation and storage	passed/failed -75 °C to +130 °C
136	GOST 30630.2.1 Clause 6, GOST 30630.0.0 Clauses 4. 7, Subclauses 8.1-8.9, GOST R IEC 60068-2-1 Clauses 4, 5, 6, 8				Resistance to the ambient temperature lower value in service	passed/failed -75 °C to +130 °C
137	GOST 30630.2.1 Clause 7, GOST 30630.0.0 Clauses 4. 7, Subclauses 8.1-8.9, GOST R IEC 60068-2-1 Clauses 4, 5, 6, 8				Resistance to the ambient temperature lower value in transportation and storage	passed/failed от -75 °C to +130 °C
138	GOST 30630.2.1 Clause 8, GOST 30630.0.0 Clauses 4, 7, Subclauses 8.1-8.9				Resistance to ambient temperature change	passed/failed -75 °C to +130 °C
139	GOST R 51369 Clause 4				Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51.
140	GOST R 51369 Clause 5	Resistance to short-term exposure to air humidity	passed/failed 60 % to 100%			
141	GOST R 51369 Clause 7	Resistance to frost with its subsequent melting	passed/failed -30 °C to -20 °C			

1	2	3	4	5	6	7
			26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.10. 29.31. 29.32	8536 8546		0.1 kV to 100 kV
142	GOST R 51369 Clause 8				Operability when exposed to glaze-ice	passed/failed -20 °C to -7 °C 10 mm to 20 mm
143	GOST 1516.2 Subclauses 4.1, 4.2, 4.4, 4.5, 7.1-7.5, 7.7	AC electrical equipment and installations for voltages greater than 3 kV	27.11 27.12 27.32 27.90	8504 8535 8536 8546	Insulation strength Test power-frequency AC voltage	passed/failed 0.1 kV to 100 kV
144	GOST R 55194 Subclause 4.1, 4.4, Clause 7	AC electrical equipment and installations for voltages greater than 3 kV	27.11 27.12 27.32 27.90	8504 8535 8536 8546	Insulation strength Test power-frequency AC voltage	passed/failed 0.1 kV to 100 kV
145	GOST R 52565 Subclause 9.1	Three-phase 50 Hz AC cir- cuit-breakers of rated voltages 3 up to and including 750 kV	27.12.10.110	8535	Geometrical dimensions Mass Protective coating condition Surface condition of external insulation parts Correctness of nameplates Correctness of marking and branding	0 mm to 15000 mm 0 kg to 5000 kg normal/defective normal/defective correct/incorrect correct/incorrect
146	GOST R 52565 Subclauses 9.2.2 – 9.2.6				Mechanical operability Closing and opening times Contact pressure Control circuit voltage Resistance Test current Useful current of control electromagnets	passed/failed 0.2 ms to 6.5 s 0 kN to 5 kN 0 V to 1000 V 1 μΩ to 1000 μΩ 0.1 mA to 100 A 0 A to 100 A
147	GOST R 52565 Subclauses 9.10.2.1, 9.10.2.2, 9.10.5				Resistance to the ambient temperature lower value Resistance to the ambient temperature upper value	passed/failed -75 °C to +130 °C passed/failed -75 °C to +130 °C
148	GOST 14254 Clause 12	Machines; instruments; and all types of miscellaneous technical products	25.11. 25.29. 25.40. 25.91. 25.92. 25.99. 26.11. 26.12. 26.20. 26.30. 26.40. 26.51.	8504 8535 8536 8546 8504 8535	Degrees of protection against access to hazardous parts of equipment designated by the first characteristic digit	passed/failed IP1X. IP2X. IP3X. IP4X
149	GOST 14254 Clause 13				Degrees of protection against external solid objects des- ignated by the first characteristic digit	passed/failed IP1X. IP2X. IP3X. IP4X
150	GOST 14254 Clause 14				Degrees of water protection designated by the second characteristic digit	IPX3. IPX4. IPX5

1	2	3	4	5	6	7		
151	GOST 14254 Clause 15		26.80. 27.11. 27.12. 27.20. 27.31. 27.32. 27.33. 27.40. 27.90. 28.12. 28.13. 28.14. 28.15. 29.10. 29.31. 29.32	8536 8546	Degrees of protection against access to hazardous parts designated by an additional letter	passed/failed A. B. C. D		
152	GOST R 52726 Subclause 8.1	AC disconnectors and earthing switches for 50 Hz power-frequency voltages greater than 1 kV and for their actuators	27.12.10.120	853530	Geometrical dimensions	0 mm to 15000 mm 0 kg to 5000 kg normal/defective normal/defective correct/incorrect correct/incorrect		
153	GOST R 52726 Subclause 8.3				Mass		Resistance Test current	1 $\mu\Omega$ to 199.9 Ω 0.1 mA to 100 A
154	GOST R 52726 Subclause 8.5				Protective insulation coating			
155	GOST R 52726 Subclause 8.6				Surface condition of external insulation parts		Operability of locking devices	passed/failed or 0 to 1 kN
156	GOST R 52726 Subclause 8.7				Correctness of nameplates			
157	GOST R 52726 Subclause 8.19				Correctness of marking and branding		Earthing circuit resistance Test current	1 $\mu\Omega$ to 1999.9 Ω 0.1 mA to 100 A
158	GOST 7746 Subclause 9.1				Electromagnetic current transformers for rated voltages 0.66 to 750 kV			
159	GOST 7746 Subclause 9.3,	Mass	Winding insulation resistance	passed/failed 3 k Ω to 1000 G Ω				

1	2	3	4	5	6	7
	GOST 8.217 Subclause 9.2					
160	GOST 7746 Subclause 9.5, GOST 8.217 Subclauses 9.3, 9.4, 9.5				Winding polarity, current and angle error Measured error range Test current	compliant/noncompliant 0.01 % to 100 % 0 A to 5000 A
161	GOST 1983 Subclause 9.1	Electromagnetic and capacitor voltage transformers	27.11.42	850431 8504320002	Geometrical dimensions Mass Protective coating condition Surface condition of external insulation parts Correctness of nameplates Correctness of marking and branding Completeness	0 mm to 15000 mm 0 kg to 5000 kg normal/defective normal/defective correct/incorrect correct/incorrect compliant/noncompliant
162	GOST 1983 Subclause 9.3				Winding insulation resistance	0 GΩ to 1000 GΩ
163	GOST 1983 Subclause 9.13				Resistance to climatic and mechanical ambient factors Test parameters: – ambient air temperature – ambient air humidity – force applied	passed/failed –60 °C to +150 °C 10 % to 98 % 0 kN to 10 kN
164	GOST 14694 Subclause 1.1	Metal-enclosed switchgear	27.12.3	853720	Geometrical dimensions Mass Correctness of nameplates Correctness of marking and branding Exterior	0 mm to 15000 mm 0 kg to 5000 kg correct/incorrect correct/incorrect compliant/noncompliant
165	GOST 14694 Subclauses 1.1, 1.5				Compliance with the design drawings and availability of technical documentation package	compliant/noncompliant 0 mm to 10000 mm
166	GOST 14694 Subclause 4.3				Operation of cabinet and withdrawable parts mecha- nisms	passed/failed 0 kN to 1 kN
167	GOST 14694 Subclause 4.4				Making and breaking operation of the main circuit switchgear	passed/failed 0 V to 690 V
168	GOST 14694 Subclause 4.5				Characteristics of switchgear and actuators	passed/failed 0.1 ms to 10 s
169	GOST 14694 Subclause 4.6				Mechanical strength of switchgear structural elements in multiple operations	passed/failed up to 10000 CO cycles
170	GOST 14694 Subclause 4.7				Operability of instruments, gears, and diagrams of auxiliary circuits	passed/failed 1000 CO cycles

1	2	3	4	5	6	7
171	GOST 14694 Subclause 4.8				Operability of locking devices	passed/failed 0 kN to 1 kN
172	GOST 14694 Subclause 4.9				Operability of fixing devices	passed/failed 0 kN to 1 kN
173	GOST 14694 Subclause 4.10				Operability of earthing switches	passed/failed 0.02 mm to 0.5 mm 1 $\mu\Omega$ to 1999.9 Ω 0.1 mA to 100 A
174	GOST 14694 Subclauses 5.1, 5.2				Insulation strength Test power-frequency AC voltage	passed/failed 0.1 kV to 100 kV
175	GOST 20248 Clause 1	Three-phase 50 Hz and 60 Hz AC packaged transformer sub- stations (PTS)	27.12.3	853720	Geometrical dimensions Mass Correctness of nameplates Correctness of marking and branding Exterior	0 mm to 15000 mm 0 kg to 5000 kg correct/incorrect correct/incorrect compliant/noncompliant
176	GOST 20248 Clause 4				Proper arrangement of operative control, protection, automatic, and alarm circuits	passed/failed
177	GOST 20248 Clause 5				Operation of switchgear and main circuit actuators	passed/failed 0.1 ms to 10 s
178	GOST 20248 Clause 6				Operability of mechanical and electrical locking de- vices	passed/failed 0 kN to 1 kN
179	GOST 20248 Clause 7				Mechanical strength of PTS structural elements in multiple operations	passed/failed 0 kN to 10 kN
180	GOST 20248 Subclause 8.4				PTS insulation strength in dew-fall conditions	passed/failed 3 k Ω to 1000 G Ω 50 V to 5000 V 0 °C to 50 °C 40 % to 98 %
181	GOST 20248 Clause 13				Check assembly, compatibility of identic withdrawa- ble parts	passed/failed operates/does not operate 0 kN to 1 kN 0 mm to 10000 mm
182	GOST IEC 61439-1 Subclause 10.2.7	Low-voltage switchgear and controlgear	27.12	8536 8537	Marking	passed/failed 0 s to 60 s
	GOST IEC 61439-1 Subclause 10.9				Insulation strength at power-frequency voltage Insulation strength at lightning impulse voltage	passed/failed 0 kV to 10 kV passed/failed

1	2	3	4	5	6	7
						0 kV to 20 kV
	GOST IEC 61439-1 Subclause 10.13				Operability of mechanical parts	passed/failed 0 kN to 1 kN

Director _____ M. E. Zheleznov